



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-155-16**

Valid from: 2025 01 12  
until: 2027 01 12

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Fixed socket outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3694-1853/22**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*  
Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2025 01 13



## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
OVE EN IEC 60309-1:2023-07-01  
OVE EN IEC 60309-2:2023-07-01  
IEC 60309-1:2021  
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Fixed socket outlets for industrial purposes**

**Type designation:**

*Rating:*

**Trademark:**

**343**  
2P+PE  
IP 67 or IP 66/IP 67  
Rated insulation voltage: 690 V  
without pilot contact  
straight flange  
see typelist

PCE / ELCEE / SIROX / METECEE

**344**  
3P+PE  
IP 67 or IP 66/IP 67  
Rated insulation voltage: 690 V  
without pilot contact  
straight flange  
see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**345**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**3435**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**3445**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

straight Flange

see typelist

PCE / ELCEE / SIROX / METECEE

**3455**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**3436**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**3446**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**3456**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

straight flange

see typelist

PCE / ELCEE / SIROX / METECEE

**443**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**444**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**445**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**4435**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**4445**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**4455**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**4436**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**4446**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**4456**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

sloping flange

see typelist

PCE / ELCEE / SIROX / METECEE

**143**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**144**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

for wall mounting

siehe typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**145**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

without pilot contact

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**1435**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

for wall mounting

siehe typelist

PCE / ELCEE / SIROX / METECEE

**1445**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**1455**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with pilot contact

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**1436**

2P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**1446**

3P+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**1456**

3P+N+PE

IP 67 or IP 66/IP 67

Rated insulation voltage: 690 V

with PCS-system

for wall mounting

see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

## Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
143 343 443  1435* 3435* 4435*  1436* 3436* 4436*	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
144 344 444  1445* 3445* 4445*  1446* 3446* 4446*	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
12	Supply from an isolating transformer	50 and 60		
145 345 445  1455* 3455* 4455*  1456* 3456* 4456*	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	220/380 250/440	50 60
		4	57/100 – 75/130	50 and 60
		5	347/600 – 400/690	50 and 60
		6	200/346 – 240/415	50 and 60
		7	277/480 – 288/500	50 and 60
		9	120/208 – 144/250	50 and 60
		10	>50	>100 - 300
		11	250/440 – 265/460	60
12	Supply from an isolating transformer	50 and 60		

\* Types 1435, 1436, 1445, 1446, 1455, 1456, 3435, 3436, 3445, 3446, 3455, 3456, 4435, 4436, 4445, 4446, 4455, 4456 only for use with electrical interlock.

### OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**Typecode**

1	4	5	5	-	6	*	*	m
---	---	---	---	---	---	---	---	---

<b>Lid axis</b>	
blank	Made of PC/ABS
m	Made of brass
<b>Contacts</b>	
blank	uncoated contacts
*	Nickel plated contacts
<b>Colour</b>	
blank	Standard type
*	Reserved for additional colours
<b>Clock position earthing contact</b>	
1	1h
2	2h
3	3h
4	4h
5	5h
6	6h
7	7h
8	8h
9	9h
10	10h
11	11h
12	12h
<b>Customer type</b>	
-	PCE
<b>Pilot contact</b>	
blank	without pilot contact
5	with pilot contact
6	with PCS-System
<b>Poles</b>	
3	3-poles
4	4-poles
5	5-poles
<b>Rated current</b>	
4	125 A
<b>Ground type</b>	
1	Wall mounted socket
3	Flanged socket straight
4	Flanged socket sloping

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.