



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-175-12**

Valid from: 2025 06 17
until: 2027 06 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Switched socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 39812**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

M. Neugebauer
Digitally signed by M. Neugebauer
on behalf of T. Neumayer
Email=m.neugebauer@ove.at
Dipl.-Ing. T. Neumayer



Wien, 2025 08 07

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

PCE Polska Sp.z.o.o.
ul Podwalna 8A
58-200 Dzierzoniow
Poland

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
ÖVE/ÖNORM EN 60309-4:2012-12-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
OVE EN IEC 60309-4:2023-04-01
IEC 60309-1:2021
IEC 60309-2:2021
IEC 60309-4:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Switched socket-outlets for industrial purposes

Type designation:

Rating:

Trademark:

960613..

Rated supply current: 16 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlet of Type 1040 or 1050

PCE / ELCEE

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

960614.. PCE / ELCEE

Rated supply current: 16 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlet of Type 1040 or 1050

960615.. PCE / ELCEE

Rated supply current: 16 A
Rated insulation voltage: 690 V
IP44 or IP44/IP54
with switch, alternatively additional with maximal
2 socket outlets of Type 1040 or 1050

960713.. PCE / ELCEE

Rated supply current: 16 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlets of Type 2034 oder 2035

960714.. PCE / ELCEE

Rated supply current: 16 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlets of Type 2034 oder 2035

960715.. PCE / ELCEE


Rated supply current: 16 A
Rated insulation voltage: 690 V
IP67 or IP66/IP67
with switch, alternatively additional with maximal
2 socket outlet of Type 2034 oder 2035

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode

960 • 1 • • • • • • • •



Special design

blank....standard design

*reserved for additional versions (shutter, colour, etc.)

Clock position earthing contact

-11h

-33h

-44h

-55h

blank....6h

-77h

-99h

-1111h

-1212h

Switch

blank....ON/OFF Switch

1reversing switch

Number of socket-outlet for household

blank....without socket-outlet

1one socket-outlet

2two socket-outlet

Optionally socket outlet for household

50without socket-outlet

4with socket-outlet 1040 (IP44), 2034* (IP67)

5with socket-outlet 1050 (IP44), 2035* (IP67)

*reserved for additional versions

Poles

3socket-outlet Type 413 (IP44), 4132 (IP67)

4socket-outlet Type 414 (IP44), 4142 (IP67)

5socket-outlet Type 415 (IP44), 4152 (IP67)

Rated current

116A

Degree of protection

6IP44 or IP44/IP54

7IP67 or IP66/IP67

Ground typ

960switched socket-outlet

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Poles	Clock position earthing contact [h]	Rated operating voltage V [V]	Frequency [Hz]	Degree of Protection [IP]
960613..	3	1	Other ratings	Other ratings	IP44 or IP44/IP54
		4	100 – 130	50 and 60	
		6*	200 – 250	50 and 60	
		7	480 – 500	50 and 60	
		9	380 – 415	50 and 60	
		12	Supply from an isolating transformer	50 and 60	
960614..	4	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 and 60	
		5	600 – 690	50 and 60	
		6*	380 – 415	50 and 60	
		7	480 – 500	50 and 60	
		9	200 – 250	50 and 60	
		11	440 – 460	60	
12	Supply from an isolating transformer	50 and 60			
960615..	5	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 and 60	
		5	347/600 – 400/690	50 and 60	
		6*	200/346 – 240/415	50 and 60	
		7	277/480 – 288/500	50 and 60	
		9	120/208 – 144/250	50 and 60	
		11	250/440 – 265/460	60	
		12	Supply from an isolating transformer	50 und 60	

* Types with max 2 x socket outlet for household only available for clock position 6h.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Type	Poles	Clock position earthing contact [h]	Rated operating voltage V [V]	Frequency [Hz]	Degree of Protection [IP]
960713..	3	1	Other ratings	Other ratings	IP67 or IP66/IP67
		4	100 – 130	50 and 60	
		6*	200 – 250	50 and 60	
		7	480 – 500	50 and 60	
		9	380 – 415	50 and 60	
		12	Supply from an isolating transformer	50 and 60	
960714..	4	1	Other ratings	Other ratings	
		3	380 440	50 60	
		4	100 – 130	50 and 60	
		5	600 – 690	50 and 60	
		6*	380 – 415	50 and 60	
		7	480 – 500	50 and 60	
		9*	200 – 250	50 and 60	
		11	440 – 460	60	
12	Supply from an isolating transformer	50 and 60			
960715..	5	1	Other ratings	Other ratings	
		3	220/380 250/440	50 60	
		4	57/100 – 75/130	50 and 60	
		5	347/600 – 400/690	50 and 60	
		6*	200/346 – 240/415	50 and 60	
		7	277/480 – 288/500	50 and 60	
		9*	120/208 – 144/250	50 and 60	
		11	250/440 – 265/460	60	
		12	Supply from an isolating transformer	50 and 60	

* Types with max 2 x socket outlet for household only available for clock position 6h or 9h.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.