



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-157-10**

Valid from: 2021 04 27  
until: 2023 04 27

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Plug for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 35786**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=[t.neumayer@ove.at](mailto:t.neumayer@ove.at)

Dipl.-Ing. T. Neumayer

Wien, 2021 06 17



## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
IEC 60309-1:1999 + A1:2005 + A2:2012  
IEC 60309-2:1999 + A1:2005 + A2:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Plug for industrial purposes**

**Type designation:**

*Rating:*

**Trademark:**

**062**

Rated current: 16 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
without minor keyway

PCE / ELCEE / METECEE

**082**

Rated current: 16 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
with minor keyway

PCE / ELCEE / METECEE

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**063**

Rated current: 16 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
without minor keyway

PCE / ELCEE / METECEE

**083**

Rated current: 16 A  
Insulation voltage: 50 V  
IP44 or IP44/IP54  
with minor keyway

PCE / ELCEE / METECEE

**0622**

Rated current: 16 A  
Insulation voltage: 50 V  
IP67 or IP66/IP67  
without minor keyway

PCE / ELCEE / METECEE

**0822**

Rated current: 16 A  
Insulation voltage: 50 V  
IP67 or IP66/IP67  
with minor keyway

PCE / ELCEE / METECEE

**0632**

Rated current: 16 A  
Insulation voltage: 50 V  
IP67 or IP66/IP67  
without minor keyway

PCE / ELCEE / METECEE

**0832**

Rated current: 16 A  
Insulation voltage: 50 V  
IP67 or IP66/IP67  
with minor keyway

PCE / ELCEE / METECEE

---

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

## Typelist

Type	Pole	Position minor key [h]	Rated operating-voltage [V]	Frequency [Hz]	Minor keyway
<b>062</b>	<b>2</b>	-	20-25	50 and 60	ohne
<b>082</b>		12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>063</b>	<b>3</b>	-	20-25	50 and 60	without
<b>083</b>		12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>0622</b>	<b>2</b>	-	20-25	50 and 60	without
<b>0822</b>		12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	
<b>0632</b>	<b>3</b>	-	20-25	50 and 60	without
<b>0832</b>		12	40-50	50 and 60	with
		4	20-25 and 40-50	100-200	
		2		300	
		3		400	
		11		>400-500	
		10		DC	

### OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).