OVE Austrian Electrotechnical Association
Eschenbachgasse 9 | 1010 Wien | Austria
ZVR: 327279890 | www.ove.at

OVE Certification
Kahlenberger Str. 2A | 1190 Wien | Austria
T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark

Certificate No.: **43-215-08**

Valid from: 2026 02 18
until: 2028 02 18

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Portable socket-outlets for industrial purposes Series SHARK**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: **TGM- VA EE 39239**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Wien, 2026 01 26

Dipl.-Ing. T. Neumayer

Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
OVE EN IEC 60309-1:2023-07-01
OVE EN IEC 60309-2:2023-07-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Portable socket-outlets for industrial purposes Series SHARK

Type designation: *Rating:*	***Trademark:***
223 Rated supply current: 32 A 2P+E IP44 or IP44/IP54 screw terminals	PCE / ELCEE / SIROX / METECEE
224 Rated supply current: 32 A 3P+E IP44 or IP44/IP54 screw terminals	PCE / ELCEE / SIROX / METECEE
225 Rated supply current: 32 A 3P+N+E IP44 or IP44/IP54 screw terminals	PCE / ELCEE / SIROX / METECEE

2232 Rated supply current: 32 A 2P+E IP67 or IP66/IP67 screw terminals	PCE / ELCEE / SIROX / METECEE
2242 Rated supply current: 32 A 3P+E IP67 or IP66/IP67 screw terminals	PCE / ELCEE / SIROX / METECEE
2252 Rated supply current: 32 A 3P+N+E IP67 or IP66/IP67 screw terminals	PCE / ELCEE / SIROX / METECEE
223TT Rated supply current: 32 A 2P+E IP44 or IP44/IP54 screwless terminals	PCE / ELCEE / SIROX / METECEE
224TT Rated supply current: 32 A 3P+E IP44 or IP44/IP54 screwless terminals	PCE / ELCEE / SIROX / METECEE
225TT Rated supply current: 32 A 3P+N+E IP44 or IP44/IP54 screwless terminals	PCE / ELCEE / SIROX / METECEE
2232TT Rated supply current: 32 A 2P+E IP67 or IP66/IP67 screwless terminals	PCE / ELCEE / SIROX / METECEE
2242TT Rated supply current: 32 A 3P+E IP67 or IP66/IP67 screwless terminals	PCE / ELCEE / SIROX / METECEE
2252TT Rated supply current: 32 A 3P+N+E IP67 or IP66/IP67 screwless terminals	PCE / ELCEE / SIROX / METECEE

2	2	3	2	-	6	TT	x	v

Contacts	
blank	uncoated contacts
v	nickel plated contacts

Colour	
blank	indicating colour
x	special design
*	reserved for additional colours

Terminals	
blank	screw terminals
TT	screwless terminals

Clock position earthing contact	
1	1 h
2	2 h
3	3 h
4	4 h
5	5 h
6	6 h
7	7 h
9	9 h
10	10 h
11	11 h
12	12 h

Customer type	
-	Trademark PCE

Degree of protection	
blank	IP44 or IP44/IP54
2	IP67 or IP66/IP67

Poles	
3	3-poles
4	4-poles
5	5-poles

Rated current	
2	32A

Ground type	
2	Connector (straight)

Typelist, Series SHARK

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
223 2232 223TT 2232TT	32	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	>50 – 250	DC	690
		4	100 – 130	50 and 60	690
		6	200 – 250	50 and 60	690
		7	480 – 500	50 and 60	690
		9	380 – 415	50 and 60	690
		10	>50	>100 - 300	690
		12	Supply from an isolating transformer	50 and 60	690
224 2242 224TT 2242TT	32	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	380 440	50 60	690
		4	100 – 130	50 and 60	690
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690
		10	>50	>100 - 300	690
		11	440 – 460	60	690
		12	Supply from an isolating transformer	50 and 60	690
225 2252 225TT 2252TT	32	1	Other ratings	Other ratings	690
		2	>50	>300 - 500	690
		3	220/380 250/440	50 60	690
		4	57/100 – 75/130	50 and 60	690
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	690
		7	277/480 – 288/500	50 and 60	690
		9	120/208 – 144/250	50 and 60	690
		10	>50	>100 - 300	690
		11	250/440 – 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690